



Certificate No: NSF2175/1119
Sample No: NSF2175

1st April 2020

Mr Sebastien Spriet
Delabie UK
7 Henderson House
Hithercroft Road
Wallingford
Oxfordshire
OX10 9DG

Dear Mr. Spriet,

Samples of the fittings described below have been subjected to relevant tests and examinations detailed in the Department of Health (DoH) Health Technical Memorandum 04-01: Supplement, Performance specification D 08: thermostatic mixing valves (healthcare premises), and after considering the test reports the NSF Technical Assessment Panel finds that the fittings so described. When correctly installed and commissioned satisfies the requirements of the DoH specification D 08.

NSF2175/1119

Range of concealed, adjustable thermostatic mixing valves. Both inlets incorporate plastic strainer and single check valve cartridge. Maximum working pressure 10.0 bar.

Application Codes: HP-SE, HP-WE, LP-SE and LP-WE

Size: ½" Male BSP inlets

Product Designations: Premix Nano 732115: thermostatic control for mixed water distribution
Premix Nano 732116: thermostatic control for mixed water distribution

Markings: Red & blue dots on inlets, cap stamped Delabie Nano

Factor: Delabie UK

Licence Expiry Date: 7th November 2024
(Providing the NSF certification annual requirements are met)

Unit 30 Fern Close | Pen-y-Fan Industrial Estate | Oakdale | Gwent | NP11 3EH | UK
T +44 (0) 1495 236 260 F +44 (0) 1495 242 499 E wales@nsf.org | www.nsf.org



NSF International

Recognises that

Delabie UK

Has had the following products certified as complying with:
The Department of Health (DH) Health Technical Memorandum 04-01: Supplement
Performance specification D 08: thermostatic mixing valves (healthcare premises) and all applicable requirements.

Range of concealed thermostatic mixing valves:

Premix Nano 732115

Premix Nano 732116

Products appearing in the NSF official listing for the TMV3 Scheme are authorised to bear the NSF Mark below.



A handwritten signature in black ink, appearing to read 'P. B. Taylor'.

Paul Taylor
Certification Director

Certificate: NSF2175/1119
Issue Date: 2nd April 2020
Expiry Date: 7th November 2024



This certificate is the property of NSF International and must be returned upon request. This certificate remains valid as long as this client has products in the listing for the referenced standard. For the most current and complete listing information, please access NSF's website (www.nsf.org).

NSF Wales Limited (Trading as NSF International)
Unit 30 Fern Close, Pen-Y-Fan Industrial Estate, Oakdale, Gwent, NP11 3EH
Tel: +44(0) 1495 236 260