

THIS IS TO CERTIFY THAT

Delabie Ltd


has had the following products Certified by BuildCert Limited
to the requirements of

**Department of Health, Health Technical memorandum HTM 04-01: Supplement,
Performance Specification D 08: Thermostatic mixing valves (healthcare
premises).**

Products covered by this certification include

H9632 concealed wall mounted shower valve

Designations of use: HP-SE and LP-SE.



Signature



Date

Certificate: BC1824/1216
Type Test and QMS
Issue Date: 19th December 2016
Expiry Date: 14th December 2021

- ⁽¹⁾ Excluding: Clause 14 Acoustic Characteristics
- ⁽²⁾ Excluding: 6.1 Marking (Acoustic & Flowrate Class)
- ⁽³⁾ Maximum Expiry Date – See Approval Letter



This approval is subject to
continuing conformity with
BuildCert requirements.
The absence of a listing on
the BuildCert website
(www.buildcert.com)
indicates that the approval
is no longer valid



110



Certificate No: BC1824/1216
Sample No: BC1824

19th December 2016

Mr. Sebastien Spriet
Delabie Ltd
7 Henderson House
Hithercroft Road
Wallingford
Oxfordshire
OX10 9DG

BuildCert Ltd

Unit 30, Fern Close,
Pen-y-Fan Industrial Estate,
Oakdale, Gwent NP11 3EH

Tel: +44 (0)1495 236260

Fax: +44 (0)1495 249234

E-mail: info@buildcert.com

Web: www.buildcert.com

Dear Mr Spriet

Samples of the fittings described below have been subjected to relevant tests and examinations detailed in the Department of Health (DoH) Health Technical Memorandum 04-01: Supplement, Performance specification D08: thermostatic mixing valves (healthcare premises), and after considering the test reports the BuildCert Technical Assessment Panel finds that the fittings so described. When correctly installed and commissioned satisfies the requirements of the DoH specification D08.

BC1824/1216

Range of wall mounted concealed thermostatic shower valves (chromium plated brass) incorporating a single sequential headwork controlling both flow and temperature using single lever operating members. Inlets incorporate flow restrictors and strainers. Maximum working pressure 10 bar.

Application Codes:	HP-SE, LP-SE
Size:	¾" BSP male inlets/outlet
Product Designations:	H9632 concealed 9639SR panel mounted
Markings:	valve base stamped with model number H9632, handle laser etched Delabie.
Manufacture:	Delabie Ltd
License Expiry Date:	14 th December 2021

(Providing BuildCert annual requirements are met)

The valves are suitable for the following applications with the following supply conditions:



Code	Operating Pressure range	Application
HP-SE LP-SE	High pressure Low pressure	Shower - maximum temperature 41°C Shower - maximum temperature 41°C
Note: Flow Pressure HP 0.5~5 bar LP 0.2~1 bar Supply Temperature Hot 55~65°C Cold ≤ 25°C Maximum Static Pressure 10bar		

The fittings described above are licensed for a period of time as indicated on the BuildCert Certificate. You will be advised when your product is due for re-assessment. The extent of any testing required for the product will be at the discretion of the Schemes' Technical Assessment Panel.

The manufacturer and/or applicant must maintain their ISO 9001 approval or the agreed quality system. Any change to the status of the quality system is required to be notified to the Scheme. A Certificate of compliance for the quality system is required to be sent to BuildCert annually.

Manufacturers or applicants may only quote in their sales literature, terms used in this letter when indicating the decision of the Panel in respect to their fittings, namely that the Technical Assessment Panel of the Scheme finds that the use of fittings, when correctly installed, commissioned and maintained, will not contravene the requirements of the model specification and that a reference to the fitting(s) will be included within the approved valve list on the BuildCert website.

A condition of licensing is that no modification to the fittings described above shall be made without first notifying the Scheme and submitting details of the modification and, if so required, samples of the fitting or unit as so modified for consideration by the Technical Assessment Panel. Failure to comply with this condition will result in the withdrawal of the BuildCert license. Resubmission will only be allowed if permitted by the BuildCert Technical Assessment Panel Committee.

Your products are required to be replicas of the samples described above, one of which is retained by the Scheme for future reference. The right is reserved to carry out quality surveillance inspections of your production arrangements.

You are asked to verify the details of your product as set out in this letter are correct and advise us of any discrepancies.

Yours faithfully



Paul Taylor
BuildCert Director